

§ 12.32

(c) *Height above streambed* means:

(1) For a dam with a spillway, the vertical distance from the lowest elevation of the natural streambed at the downstream toe of the dam to the maximum water storage elevation possible without any discharge from the spillway. The maximum water storage elevation is:

(i) For gated spillways, the elevation of the tops of the gates;

(ii) For ungated spillways, the elevation of the spillway crest or the top of any flashboards, whichever is higher;

(2) For a dam without a spillway, the vertical distance from the lowest elevation of the natural streambed at the downstream toe of the dam to the lowest point on the crest of the dam.

(d) *Gross storage capacity* means the maximum possible volume of water impounded by a dam with zero spill, that is, without the discharge of water over the dam or a spillway.

(e) The Director of the Office of Energy Projects Licensing may, for good cause shown, grant a waiver of the 10 year requirement in paragraph (a)(2) of this section. Any petition for waiver under this paragraph must be filed in accordance with §1.7(b) of this chapter.

[Order 122, 46 FR 9036, Jan. 28, 1981, as amended at 49 FR 29370, July 20, 1984]

§ 12.32 General inspection requirement.

In accordance with the procedures in §12.35, the project works of each development to which this subpart applies, excluding transmission and transformation facilities and generating equipment, must be periodically inspected and evaluated by or under the responsibility and direction of at least one independent consultant, who may be a member of a consulting firm, to identify any actual or potential deficiencies, whether in the condition of those project works or in the quality or adequacy of project maintenance, surveillance, or methods of operation, that might endanger public safety.

§ 12.33 Exemption.

(a) Upon written request from the licensee, the Director of the Office of Energy Projects Licensing may grant an exemption from the requirements of this subpart in extraordinary cir-

18 CFR Ch. I (4-1-12 Edition)

cumstances that clearly establish good cause for exemption.

(b) Good cause for exemption may include the finding that the development in question has no dam except dams that meet the criteria for low hazard potential as defined by the Corps of Engineers in 33 CFR part 222.

[Order 122, 46 FR 9036, Jan. 28, 1981, as amended at 49 FR 29370, July 20, 1984]

§ 12.34 Approval of independent consultant.

At least 60 days before the initiation of an inspection under this subpart, the licensee must submit to the Director of the Office of Energy Projects Licensing for approval, with a copy to the Regional Engineer, a detailed resume that (a) describes the experience of the independent consultant; and, (b) shows that the consultant is an independent consultant as defined in §12.31(a).

[Order 122, 46 FR 9036, Jan. 28, 1981, as amended at 49 FR 29370, July 20, 1984]

§ 12.35 Specific inspection requirements.

(a) *Scope of inspection.* The inspection by the independent consultant shall include:

(1) Due consideration of all relevant reports on the safety of the development made by or written under the direction of Federal or state agencies, submitted under Commission regulations, or made by other consultants;

(2) Physical field inspection of the project works and review and assessment of all relevant data concerning:

(i) Settlement;

(ii) Movement;

(iii) Erosion;

(iv) Seepage;

(v) Leakage;

(vi) Cracking;

(vii) Deterioration;

(viii) Seismicity;

(ix) Internal stress and hydrostatic pressures in project structures or their foundations or abutments;

(x) The functioning of foundation drains and relief wells;

(xi) The stability of critical slopes adjacent to a reservoir or project works; and

(xii) Regional and site geological conditions; and

(3) Specific evaluation of: